

LOG SHEET

Public Pool/Spa Log Sheet (Chlorine)

Operator: _____

Date: _____

Time	Water Temp ($<40^{\circ}\text{C}$)	Free Available Chlorine Pool (0.5-10ppm) Spa (5-10ppm)	Total Chlorine (ppm)	pH (7.2-7.8)	Total Alkalinity (80-120ppm)	ORP Reading (600-900mV)	Water Clarity Black disc in pool from (9m)	Initials

*CC=TC-FAC: Calculated combined chlorine (CC) should be $<1.0\text{ppm}$.

Daily Log Requirements (Prior to Daily Operation)

Emergency Phone Working: ☐yes ☐no

Ground Fault Detector Working: ☐yes ☐no

Daily Make-Up Water Required:

Total # of Bathers: _____

x15 L: _____

Make-Up Water: _____

Weekly Log Requirements (Outdoor Pools Only)

Cyanurate Stabilizer: _____ ppm

Note: When stabilization is present in pool, FAC must be 1.0-10ppm

Monthly Log Requirements

Emergency Stop Button: ☐yes ☐no

Outlet Covers: ☐yes ☐no

Vacuum Relief Mechanism (Spa Only): ☐yes ☐no

Daily Make-Up Water Added:

_____ - _____ = _____
 Today's Reading: Previous Day's Reading Total Water Added

Accidents/Injuries/Rescues/Breakdowns:

Chemicals Added:

